

Case study for HOTEL Wasted GREY / BLACK Water Heat Recovery.

By DDI Heat
Exchangers Inc.

Grey and Black Water - (now Wasted)

SAMPLE CASE

Number of Hotel rooms or Hospital beds 500

With restaurant and Laundry

Very small flow 41 usg/min (2.6 L/S)
Temp 86 deg F (30 deg C)

Cold Water from underground

Flows to Central Boiler

Temp 45 deg F (7.2 deg C)
Delta T 10 deg F (5.6 deg C)

Pressure drop 0.1 PSI (0.2 ft water)

Weighed Capacity 200,000 BTUH (60 KW)

Max **Design capacity 2 Million BTUH (586 KW)**

Max Design flow 1,000 usgpm (63 L/S)
Pressure drop at Max flow 17 psi (39 ft water)
Max Design pressure 50 psi (115 ft water)

Assumed Variables

El Utility Cost 0.06 USD/KWh
NG Utility Cost 0.25 USD/m3
NG plant eff. 75 %

Equipment max

DDI Heat Exchanger 30- 1,000 usgpm
Space of 1 car garage (Design can be smaller)
14 ft long x 4.8 ft wide x 6.6 ft high
4.2 meter long x 1.5 meter wide x 2.1 meter high

Need extra 3 ft (1 meter) in one length, free space for cleaning
Weight 17,600 lb. (7,980 kg)
Design Pressure max 50 psi (35 meter)

Economics

Cost

DDI Heat Exchanger 60,000 \$ US
Installation 10,000 \$ US
Operation 1,000 \$ US/ year

=====

Total Cost = 71,000 \$ US

Savings

60 KW x 24 hours x 364 days = 525,000 KW / Year
525,000 KW x 0.06\$ = 31,500 \$ US / year

ROI 2.2 years

**Plus MARKETING benefit to the Hotel / Hospital
Green Energy via Wasted Heat Recovery.**

Erwin Schwartz / B. Eng. / Management.

President

DDI-Heat Exchangers Inc.

Tel: 514-696-7961 Cell: 514-531-3794

Email: erwin@ddi-heatexchangers.com

www.ddi-heatexchangers.com

www.energyrecoveryolution.com

"RECTANGULAR, SQUARE, CUBE"™
Don't WASTE the WASTE, use DDI HEAT RECOVERY Exchangers